



The State of New Hampshire  
**Department of Environmental Services**



**Robert R. Scott, Commissioner**

**Owner/Responsible Party:**  
CHRISTOPHER KELLAN  
TIMERLANE REGIONAL SCHOOL  
DISTRICT  
30 GREENOUGH RD  
PLAISTOW, NH 03865  
Via email:  
christopher.kellan@timberlane.net

**NOTICE OF VIOLATION  
Immediate Action Required**

**Public Water System:**  
POLLARD ELEMENTARY SCH  
**PWS ID:** 1935010  
**Location:** PLAISTOW

**Date Issued:** August 8, 2022

The New Hampshire Department of Environmental Services' ("NHDES") records indicate that the water samples results submitted in the monitoring period listed below exceeded a Maximum Contaminant Level ("MCL") for drinking water. The following violation has occurred:

**Exceedance:** Quarter 1- 2022  
**Violation of NH Admin. Rule:** Env-Dw 712

Site ID	Contaminant	MCL	Sample Result	Date Collected
003	Perfluorooctanoic Acid (PFOA)	12 ng/L	13 ng/L	March 1, 2022

**Required Actions**

Action	When	Rule Citation
1. Perform Public Notice	Within 30 days of the date of this notice	Env-Dw 801
2. Certify that public notice was performed	Within 10 days of performing public notice	Env-Dw 801

**Additionally, quarterly sampling for PFAS is now required; check your Master Sampling Schedule**

You can access much of your public water system's information (including the sampling schedule and results) plus any needed forms on the NHDES [OneStop](#). Simply [click here](#) and enter the PWSID. The necessary public notice template can be found [here](#), then click "Download Mail-In Form".

Once NHDES receives the written documentation requested above, NHDES records will be updated and the violation will be closed. Further violations or failure to complete the required actions listed above may result in NHDES issuing a Letter of Deficiency, Administrative Order, seeking an Administrative Fine up to \$4,000 per violation, and/or referring the system to the N.H. Department of Justice. Any further enforcement actions taken by the Department may be posted on the NHDES website for a period of five years.

Please contact me if you have any questions.

Issued by:

Tricia Madore  
Monitoring Section  
[dwmonitoring@des.nh.gov](mailto:dwmonitoring@des.nh.gov)  
(603) 271-3907

Drinking Water and Groundwater Bureau

ec: Town of PLAISTOW, Health Officer  
DANIEL WOJCIK JR, Primary Operator  
KARL INGOLDSBY, Primary Contact