



GRANITE STATE ANALYTICAL SERVICES, LLC

22 Manchester Road, Unit 2, Derry, NH 03038

Phone (800) 699-9920

(603) 432-3044

Fax (603) 434-4837

<http://www.granitestateanalytical.com/>

DRINKING WATER COMPLIANCE REPORT

DATE PRINTED: 10/23/2017 CHEMICAL RESULTS FOR THE 4th QUARTER 2017

SAMPLE ID#: 1710-02323-001 LAB ID#: 1015

SAMPLED BY: Morgan, Leslie-PWW

SAMPLE CATEGORY: Routine Sample

SYSTEM NAME: Atkinson Academy Sch EPA ID #: 0115010

SYSTEM TOWN: Atkinson DATE & TIME COLLECTED: 10/19/2017 11:34AM

SAMPLE AGENT #: 913-2378 DATE & TIME RECEIVED: 10/20/2017 10:05AM

SAMPLE LOCATION: 502 Mechanical Rm WATER SYS TYPE: Non-Transient, Non-Community

RECEIPT TEMP: ON ICE 4.4° CELSIUS

BAR CODE: 20170927001-001 CLIENT JOB #

Legend

- Passes ✓
- Fails EPA Primary ⊗
- Fails EPA Secondary ▽
- Fails State Guideline ✕
- Attention ⚠

Test Description	Results	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Arsenic*	0.0036	mg/L	✓		0.001	0.010 mg/L	EPA 200.8	SR-NH	10/23/17 1:37PM

The results presented in this report relate to the samples listed above in the condition in which they were received.
 RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.

Data Qualifier (DQ) Flags: None

* NELAP Accredited Analysis




 Donald A. D'Anjou, Ph. D.
 Laboratory Director