



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

Laboratory Report

Pennichuck Water Works
25 Walnut St
Nashua, NH 03060

Date Printed: 03/03/2022
Work Order #: 2203-00241
Client Job #:
Date Received: 03/02/2022
Sample collected in: New Hampshire

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:

Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:

Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

SAMPLE STATE SPECIFIC NOTES:

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.



Donald A. D'Anjou, Ph. D.
Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

DATE PRINTED: 03/03/2022

DRINKING WATER BACTERIA REPORT

BACTERIA RESULTS FOR THE MONTH OF March, 2022

SYSTEM NAME: Sandown North Elementary Sch
SYSTEM EPA ID#: 2085040
SYSTEM TOWN: Sandown
SAMPLE CATEGORY: Routine Sample
SAMPLING AGENT: Kelly, Jayson
SAMPLE AGENT #: 603-913-2385

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▼
Fails State Guideline	✕
Attention	⚠

LABORATORY ID# 1015 ANALYST: DP-NH
DATE & TIME RECEIVED: 03/02/2022 10:45AM
WATER SYS TYPE: Non-Transient, Non-Community
METHOD: SM 9223B TEST UNITS: P-A/100mL
MCL: No Limit MDL (RL): Absent
Media: (Colilert®-18) 20th ED

SAMPLE LOCATION	BAR CODE NUMBER	DATE/TIME COLLECTED	LABORATORY SAMPLE ID#	CLIENT JOB #	DATE & TIME ANALYZED	TOTAL COLIFORM	Pass DQ /Fail	ECOLI	Pass DQ /Fail
001 Teachers Lounge Bathroom Sink	20220225145-001	03/01/2022 09:35AM	2203-00241-001		03/03/2022 08:19AM	Absent	✓	Absent	✓



Donald A. D'Anjou, Ph. D.
Laboratory Director