



# GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038  
Phone (800) 699-9920 | (603) 432-3044 website [www.granitestateanalytical.com](http://www.granitestateanalytical.com)

## Laboratory Report

**Pennichuck Water Works**  
25 Walnut St  
Nashua, NH 03060

Date Printed: 03/16/2022  
Work Order #: 2203-02051  
Client Job #:  
Date Received: 03/15/2022  
Sample collected in: New Hampshire

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the \* symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

**A & L Laboratory:**

*Identified by ME in Analyst Column*  
155 Center Street, Auburn, Maine 04210  
[www.allaboratory.com](http://www.allaboratory.com)

**Granite State Analytical Services LLC:**

*Identified by NH in Analyst Column*  
22 Manchester Road, Derry, NH 03038  
[www.granitestateanalytical.com](http://www.granitestateanalytical.com)

**ANALYSIS RELATED NOTES:**

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

**SAMPLE STATE SPECIFIC NOTES:**

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.



Donald A. D'Anjou, Ph. D.  
Laboratory Director



# GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038  
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

DATE PRINTED: 03/16/2022

## DRINKING WATER BACTERIA REPORT

BACTERIA RESULTS FOR THE MONTH OF March, 2022

SYSTEM NAME: TIMBERLANE REGIONAL HS  
SYSTEM EPA ID#: 1935030  
SYSTEM TOWN: Plaistow  
SAMPLE CATEGORY: Routine Sample  
SAMPLING AGENT: Rheume, Andrew  
  
SAMPLE AGENT #: 603-913-2378

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▼
Fails State Guideline	✕
Attention	⚠

LABORATORY ID# 1015 ANALYST: RS-NH  
DATE & TIME RECEIVED: 03/15/2022 09:08AM  
WATER SYS TYPE: Non-Transient, Non-Community  
METHOD: SM 9223B TEST UNITS: P-A/100mL  
MCL: No Limit MDL (RL): Absent  
Media: (Colilert®-18) 20th ED

SAMPLE LOCATION	BAR CODE NUMBER	DATE/TIME COLLECTED	LABORATORY SAMPLE ID#	CLIENT JOB #	DATE & TIME ANALYZED	TOTAL COLIFORM	Pass DQ /Fail	ECOLI	Pass DQ /Fail
002 KITCHEN HAND WASH SINK	20220225182-001	03/14/2022 11:30AM	2203-02051-001		03/16/2022 07:59AM	Absent	✓	Absent	✓
002 KITCHEN HAND WASH SINK	20220225182-001	03/14/2022 11:30AM	2203-02051-001		03/14/2022 11:30AM	Free Chlorine - Field		0.16	
001 Nurses Sink	20220225182-002	03/14/2022 11:40AM	2203-02051-002		03/16/2022 07:59AM	Absent	✓	Absent	✓
001 Nurses Sink	20220225182-002	03/14/2022 11:40AM	2203-02051-002		03/14/2022 11:40AM	Free Chlorine - Field		0.13	



Donald A. D'Anjou, Ph. D.  
Laboratory Director