



GRANITE STATE ANALYTICAL SERVICES, LLC

22 Manchester Road, Unit 2, Derry, NH 03038

Phone (800) 699-9920

(603) 432-3044

Fax (603) 434-4837

<http://www.granitestateanalytical.com/>

DRINKING WATER COMPLIANCE REPORT

DATE PRINTED: 09/18/2017 CHEMICAL RESULTS FOR THE 3rd QUARTER 2017 LAB ID# 1015
 SAMPLE ID#: 1709-01612-001 DATE & TIME COLLECTED: 09/13/2017 10:10AM
 SAMPLED BY: Morgan, Leslie-PWW DATE & TIME RECEIVED: 09/13/2017 4:02PM
 SYSTEM EPA ID #: 1935030
 SAMPLE CATEGORY: Routine Sample WATER SYSTEM TYPE: Non-Transient, Non-Community
 SYSTEM NAME: TIMBERLANE REGIONAL HS
 SAMPLE AGENT #: 913-2378 SYSTEM TOWN: Plaistow
 RECEIPT TEMP: 21.2° CELSIUS SAMPLE LOCATION: 511 DEP Tap AF Trtmt/Boiler Room/001
 BAR CODE: 20170818002-001

CLIENT JOB

Test Description	Results	Test Units	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Arsenic*	0.0078	mg/L		0.001	0.010 mg/L	EPA 200.8	SR-NH	09/15/17 8:32PM

The results presented in this report relate to the samples listed above in the condition in which they were received.

RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.

Data Qualifier (DQ) Flags: None

* NELAP Accredited Analysis



Donald A. D'Anjou, Ph. D.
Laboratory Director

This analysis meets NELAP requirements except as noted.

State Certifications: | NH 1015 | MA M-NH003 | ME NH00003 | RI 101513 | VT VT-101507 |

This certificate shall not be reproduced, except in full, without the written approval of Granite State Analytical Services, LLC