

# PENNICHUCK WATER WORKS LAB

200 Concord St., Nashua, NH 03064  
603-913-2378

Lab Contact: Gary Tetley, Laboratory Directory

NC (2)

Date Printed: October 12, 2017

NH Laboratory ID # 1030

## DRINKING WATER BACTERIA REPORT Bacteria Results for the Month of: October 2017

Receipt Temperature: on Ice at 16°Celsius

SYSTEM NAME TIMBERLANE REGIONAL HS WATER SYSTEM TYPE: NC/NT

Method: SM 9223 B Collert 18 \*

EPA #: 1935030  
SAMPLE TOWN: Plaistow  
SAMPLE PURPOSE: RT

SAMPLING AGENT: Andrew Rheaume  
SAMPLING AGENT PHONE #: 603-913-2378  
CHLORINATED SYSTEM: Yes

Test Units: P-A/100mL  
Analyst: Jane Vukelich  
Date & Time Received: 10-11-17/15:22  
Received By: Jane Vukelich

Site ID #	Sample Location	Chlorine Residual	Sample ID Number	Date & Time Collected	Date & Time Prepared	Date & Time Analyzed	Total Coliform	E. Coli
001	Nurses Sink	0.00	20170926160-002	10-11-17 /11:20	10-11-17/15:29	10-12-17/10:39	ABSENT	ABSENT
002	HANDWASH SINK /KITCHEN	0.00	20170926160-001	10-11-17 /11:15	10-11-17/15:29	10-12-17/10:39	ABSENT	ABSENT

Comments:

\*NELAC Accredited Analysis

Authorized by:

