

PENNICHUCK WATER WORKS LAB

200 Concord St., Nashua, NH 03064
603-913-2378

Lab Contact: Gary Tetley, Laboratory Directory

NC 2

Date Printed: October 12, 2017

NH Laboratory ID # 1030

Receipt Temperature: on ice at 16°Celsius

DRINKING WATER BACTERIA REPORT Bacteria Results for the Month of: October 2017

SYSTEM NAME TIMBERLANE MIDDLE SCH

WATER SYSTEM TYPE: NC/NT

Method: SM 9223 B Collert 18 *

EPA #: 1935020

SAMPLING AGENT: Andrew Rheaume

Test Units: P-A/100mL

SAMPLE TOWN: Plaistow

SAMPLING AGENT PHONE #: 603-913-2378

Analyst: Jane Vukelich

SAMPLE PURPOSE: RT

CHLORINATED SYSTEM: No

Date & Time Received: 10-11-17/15:22

Received By: Jane Vukelich

Site ID #	Sample Location	Chlorine Residual	Sample ID Number	Date & Time Collected	Date & Time Prepared	Date & Time Analyzed	Total Coliform	E. Coli
001	Nurses Office Sink		20170926158-002	10-11-17 /11:20	10-11-17/15:29	10-12-17/10:39	ABSENT	ABSENT
006	HANDSINK /KITCHEN PREP AREA		20170926158-001	10-11-17 /11:15	10-11-17/15:29	10-12-17/10:39	ABSENT	ABSENT

Comments:

*NELAC Accredited Analysis

Page 1 of 1

Authorized by:

