

Timberlane Regional School District

Invitation for Bid for:

Supply and Deliver Two (2) Bosch commercial stainless steel condensing boilers Series SSB – Natural gas fired

Date Posted: 5/18/2018

Date Due: 5/25/2018 10:00AM

Bid Opening: 5/25/2018 10:00AM

Bids shall be addressed in a *sealed envelope, no later than May 25, 2018 at 9:45am* to:

Superintendent of Schools

30 Greenough Rd.

Plaistow, NH 03865

IFB: (2) Bosch Boilers

Bid must include the following:

Qty: 2

- **Model SSB1000TL Cascading boiler modules 20:1 turndown ratio**
- **1982 BTUH Gross output**
- **1048 MBH gas input**

- Dual 316L Stainless steel heat exchanger each module Integral boiler pumps, 2 per module
- Integral controls – 7” touchscreen display
- 2 wire cascade control link
- Manual reset high limit
- Flow sensors each module
- High and low gas pressure safety switches
- 75 lb. relief valve
- O.A. sensor for reset control
- Low water cutoff
- Internal hydraulic manifold piping (water, gas & flue) Venting adaptors
- 10 Year heat exchanger warranty
- 120volt/1/60

- BACnet controls
- ASME, CSA, AHRI approvals

****Bid shall include all freight and shipping charges. The District will supply shipping address upon award of bid.***

All questions regarding this IFB shall be directed via email to:
Thomas F. Geary III
Business Operation Coordinator, SAU 55
thomas.geary@sau55.net

Bid Price

Company Name

Signature

Date