

GRANITE STATE ANALYTICAL SERVICES, LLC

22 Manchester Road, Unit 2, Derry, NH 03038

Phone (800) 699-9920

(603) 432-3044

Fax (603) 434-4837

<http://www.granitestateanalytical.com/>

DATE PRINTED: 10/18/2017

LEAD AND COPPER RESULTS

LAB ID#: 1015

COMPLIANCE PERIOD: CHEMICAL RESULTS FOR THE 4th QUARTER 2017

SYSTEM NAME: Pollard Elementary Sch
 SYSTEM TOWN: Plaistow
 SAMPLE CATEGORY: Routine Sample
 SAMPLING AGENT: Duffy, Sarah
 by GSA QCM App. I
 SAMPLE AGENT #: 603-432-3044
 RECEIPT TEMP: 21.0° CELSIUS

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▽
Fails State Guideline	✕
Attention	⚠

EPA ID #: 1935010
 WATER SYSTEM TYPE: Non-Transient, Non-Community
 TEST UNITS: mg/L ANALYST: SR-NH
 METHOD: Copper EPA 200.8 Lead EPA 200.8
 MCL: Copper 1.30 mg/L, Lead 0.015 mg/L
 MDL (RL): Copper 0.001 mg/L, Lead 0.001 mg/L
 DATE & TIME RECEIVED: 10/12/2017 8:27AM

SAMPLE LOCATION	DATE/TIME COLLECTED	LABORATORY SAMPLE ID#	CLIENT JOB #	LEAD *	Pass /Fail	DQ	DATE ANALYZED	COPPER *	Pass /Fail	DQ	DATE ANALYZED
004 Classroom 104, 20171012001-001	10/12/2017 6:55AM	1710-01570-001		0.010	✓		10/17/17	0.0759	✓		10/17/17
006 CLASSROOM 106, 20171012001-002	10/12/2017 6:55AM	1710-01570-002		<0.001	✓		10/17/17	0.0140	✓		10/17/17
008 ROOM 108 /MEDIA, 20171012001-003	10/12/2017 6:55AM	1710-01570-003		0.0029	✓		10/17/17	0.0495	✓		10/17/17
010 CLASSROOM 107, 20171012001-004	10/12/2017 6:55AM	1710-01570-004		0.0061	✓		10/17/17	0.0618	✓		10/17/17
012 Classroom 310, 20171012001-005	10/12/2017 6:55AM	1710-01570-005		0.0067	✓		10/17/17	0.0580	✓		10/17/17
018 CLASSROOM 303, 20171012001-006	10/12/2017 6:55AM	1710-01570-006		0.0019	✓		10/17/17	0.0410	✓		10/17/17
022 BUBBLER 1ST FLR BY NURSE, 20171012001-007	10/12/2017 6:55AM	1710-01570-007		<0.001	✓		10/17/17	0.0054	✓		10/17/17
024 BUBBLER 1ST FLR BY ATTIC (1ST GR), 20171012001-008	10/12/2017 6:55AM	1710-01570-008		0.0100	✓		10/17/17	0.0809	✓		10/17/17
026 BUBBLER IN GYM, 20171012001-009	10/12/2017 6:55AM	1710-01570-009		<0.001	✓		10/17/17	0.0200	✓		10/17/17


The results presented in this report relate to the samples listed above in the condition in which they were received.
 RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.

Data Qualifier (DQ) Flags: None

* NELAP Accredited Analysis



Donald A. D'Anjou, Ph. D.
Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC

22 Manchester Road, Unit 2, Derry, NH 03038

Phone (800) 699-9920

(603) 432-3044

Fax (603) 434-4837

<http://www.granitestateanalytical.com/>

DATE PRINTED: 10/18/2017

LEAD AND COPPER RESULTS

LAB ID#: 1015

COMPLIANCE PERIOD: CHEMICAL RESULTS FOR THE 4th QUARTER 2017

SYSTEM NAME: Pollard Elementary Sch
 SYSTEM TOWN: Plaistow
 SAMPLE CATEGORY: Routine Sample
 SAMPLING AGENT: Duffy, Sarah
 by GSA QCM App. I
 SAMPLE AGENT #: 603-432-3044
 RECEIPT TEMP: 21.0° CELSIUS
 SAMPLE LOCATION

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▽
Fails State Guideline	✕
Attention	⚠

EPA ID #: 1935010
 WATER SYSTEM TYPE: Non-Transient, Non-Community
 TEST UNITS: mg/L ANALYST: SR-NH
 METHOD: Copper EPA 200.8 Lead EPA 200.8
 MCL: Copper 1.30 mg/L, Lead 0.015 mg/L
 MDL (RL): Copper 0.001 mg/L, Lead 0.001 mg/L
 DATE & TIME RECEIVED: 10/12/2017 8:27AM

SAMPLE LOCATION	DATE/TIME COLLECTED	LABORATORY SAMPLE ID#	CLIENT JOB #	LEAD *	Pass /Fail	DQ	DATE ANALYZED	COPPER *	Pass /Fail	DQ	DATE ANALYZED
028 BUBBLER 2ND FLR BY ELEVATOR, 20171012001-010	10/12/2017 6:55AM	1710-01570-010		0.0016	✓		10/17/17	0.0282	✓		10/17/17

The results presented in this report relate to the samples listed above in the condition in which they were received.
 RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.

Data Qualifier (DQ) Flags: None

* NELAP Accredited Analysis



Donald A. D'Anjou, Ph. D.
Laboratory Director