GRANITE STATE ANALYTICAL SERVICES, LLC
22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 (603) 432-3044 Fax (603) 434-4837
http://www.granitestateanalytical.com/

DRINKING WATER COMPLIANCE REPORT

CHEMICAL RESULTS FOR THE 1st QUARTER 2018

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▽
Fails State Guideline	✕
Attention	⚠

DATE PRINTED: 02/09/2018
SAMPLE ID#: 1802-00489-001
LAB ID#: 1015
SAMPLED BY: Crane, Matthew-PWW
SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Sandown North Elementary Sch
EPA ID #: 2085040
SYSTEM TOWN: Sandown
DATE & TIME COLLECTED: 02/06/2018 11:00AM
SAMPLE AGENT #: 913-2378
DATE & TIME RECEIVED: 02/07/2018 8:25AM
SAMPLE LOCATION: 001 Source Tap in Pumproom /001
WATER SYS TYPE: Non-Transient, Non-Community
RECEIPT TEMP: ON ICE 1.0° CELSIUS
BAR CODE: 20171228277-001
CLIENT JOB #

Test Description	Results	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Arsenic*	0.0077	mg/L	✓		0.001	0.010 mg/L	EPA 200.8	BB-NH	02/08/18 4:24PM

RECEIVED
MAR 1 5 2018
By

The results presented in this report relate to the samples listed above in the condition in which they were received.
RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.

Data Qualifier (DQ) Flags: None

*** NELAP Accredited Analysis**

NELAP ACCREDITED TNI LABORATORY

Donald A. D'Anjou, Ph. D.
Laboratory Director

This analysis meets NELAP requirements except as noted.
State Certifications: | NH 1015 | MA M-NH003 | ME NH00003 | RI 101513 | VT VT-101507 |
This certificate shall not be reproduced, except in full, without the written approval of Granite State Analytical Services, LLC