



# GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038

Phone: (800) 699-9920 | (603) 432-3044

website: www.granitestateanalytical.com

## DRINKING WATER COMPLIANCE REPORT

DATE PRINTED: 04/08/2019 CHEMICAL RESULTS FOR THE 2nd QUARTER 2019  
SAMPLE ID#: 1904-00560-001 LAB ID#: 1015  
SAMPLED BY: Crane, Matthew-PWW

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▽
Fails State Guideline	✕
Attention	⚠

SAMPLE CATEGORY: Routine Sample  
SYSTEM NAME: Atkinson Academy Sch EPA ID #: 0115010  
SYSTEM TOWN: Atkinson DATE & TIME COLLECTED: 04/03/2019 12:15PM  
SAMPLE AGENT #: 913-2378 DATE & TIME RECEIVED: 04/04/2019 11:07AM  
SAMPLE LOCATION: 502 MECHANICAL RM DEP TAP AF TRT/002 WATER SYS TYPE: Non-Transient, Non-Community  
RECEIPT TEMP: 20° CELSIUS  
BAR CODE: 20190328003-001 CLIENT JOB #

Test Description	Results	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Arsenic*	0.0033	mg/L	✓		0.001	0.010 mg/L	EPA 200.8	JLR-NH	04/08/19 10:49AM

The results presented in this report relate to the samples listed above in the condition in which they were received.  
RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.

Data Qualifier (DQ) Flags: None

\* NELAP Accredited Analysis



Donald A. D'Anjou, Ph. D.  
Laboratory Director

This analysis meets NELAP requirements except as noted.  
State Certifications: | NH 1015 | MA M-NH003 | ME NH00003 | RI 101513 | VT VT-101507 |  
This certificate shall not be reproduced, except in full, without the written approval of Granite State Analytical Services, LLC